检测报告

编号: SDHL2211022360HI　　日期:2022 年 11 月 07 日　　页码：第 1 页共 2 页

保定巨恒塑料制造有限公司
河北省保定市雄县东城经济开发区

样品描述　　：同质透心塑胶地板

生产厂家　　：江苏恒冉新材料有限公司

以上样品及信息由客户提供及确认，SGS 不承担证实客户提供信息的准确性、适当性、可靠性和(或)完整性责任。

****

收样日期　　：2022 年 10 月 07 日

检测日期　　：2022 年 10 月 09 日至 2022 年 10 月 18 日

执行检测　　：按申请者要求进行检测

测试结果总结

编号	测试项目	测试要求(方法)	测试结果	备注
1	残余凹陷	ISO 10581-2019 表 2 & ISO 24343-1:2007	符合	/
详细的测试结果请看附页				

通标标准技术服务有限公司顺德分公司
授权代表签署

扫码查看在线报告

SDHL2211022360HI

赵维勇
授权签字人

此报告结果仅对测试样品负责

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention:To check the authenticity of testing / inspection report & certificate, please contact us at telephone:(86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC Standards Technical Services Co., Ltd. Shunde Branch Hardlines
1F,1st Building,European Industrial Park,No.1 Shunhe South Road,Wusha Section,Daliang Town,Shunde,Foshan,Guangdong,China 528333 t (86-757)22805888 f (86-757)22805858 www.sgsgroup.com.cn
中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园一号厂房首层 邮编: 528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com

测试信息：

样品描述：见照片

1. 测试项目：残余凹陷

测试方法：ISO 10581-2019 表 2 & ISO 24343-1:2007

测试条件：

标记样品的测量位置并测量其中心的初始厚度，精确到 0.01mm，记录为初始厚度值 t_0。将样品放在平台，然后把环形砝码放在样品上。平稳施加总负荷 500N，并于 2 秒内开始计时。加载 150 分钟后记录此时的压痕深度，精确至 0.01mm，卸去载荷并将样品从平台上移开。待样品再静置 150 分钟后，用合适的测量设备在相同位置测量样品的最终厚度 t_1。

测试结果：

残余凹陷（mm）	标准 ISO 10581-2019 表 2 要求	结论
0.04	≤0.1mm	符合

备注：所有测试试样均从样品中裁取。

样品照片：



样品原照

备注：

1.本报告是编号为 SDHL2211022359HI 英文检测报告的中文译本，如有歧义，以英文版本为准。

2. 除非另有说明，参照 ILAC-G8:09/2019，使用简单接受（w=0）的二元判定规则进行符合性判定。

3.检测报告仅用于客户科研、教学、内部质量控制、产品研发等目的，仅供内部参考。

报告结束

检验检测专用章 Inspection & Testing Services

SGS-CSTC Standards Technical Services Co., Ltd. Shunde Branch Hardlines

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention:To check the authenticity of testing / inspection report & certificate, please contact us at telephone:(86-755) 8307 1443, or email: CN.Doccheck@sgs.com

1/F,1st Building,European Industrial Park,No.1 Shunhe South Road,Wusha Section,Daliang Town,Shunde,Foshan,Guangdong,China 528333 t (86-757)22805888 f (86-757)22805858 www.sgsgroup.com.cn

中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园一号厂房首层 邮编: 528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com

Member of the SGS Group (SGS SA)